

Convention Center Authority

RFP Questions:

1. Please confirm that the 'side elevations' of the canopy will be open, not requiring any screening, etc.
 - Will want these sides to remain open.
2. Please confirm where the water downspouts off of the canopy will be taken to
 - Preference to utilize existing downspouts/drainage within the building.
3. We plan to offer two options:
 1. Connection to vestibule to be under cover
 2. Stepped back version with less PV production as well as open area
 - TBD
4. Is there an overall schedule of construction that RICC would like to see?
 - No preferred schedule
5. Confirm that the steel will be galvanized steel.
 - The preferred steel would be galvanized but are looking for steel to last 25-30 years minimum.
6. Confirm that the flashing will need to be removed and then reinstalled around the perimeter of the wall.
 - TBD
7. Confirm that this contract includes removing of existing lights and reinstalling different types of lights below the canopy.
 - Yes, new lighting is a preference.
8. Does the Authority or its consultant have a preference on manufacturers/vendors for major equipment such as inverters, panelboards, and transformers?
 - Preference is Tier 1 equipment with bankable warranties.
9. Has the Authority or its consultant investigated potential interconnection points for the project? Is the project required to be in front of or behind the meter?
 - No on Interconnection Point, and no requirement for FTM vs. BTM – whichever option yields the best RFP requirements.
10. Does the authority prefer a full roof coverage or is there a targeted installed capacity?
 - TBD
11. What is the estimated construction budget?
 - TBD